

Mt Sherman Water Board Mtg

Jan 9 2006

Water Operators Report

Fixed leak on the three inch line Observation Meter by the DeMuth line. The valve box was run over and the meter froze and Broke.

The James line is installed, pressure tested and ready to be bled and water samples will be taken this week. Tommy James will Be the only water user at this time. His house is being built.

The cost of placing a shut off valve and box is about \$60.00.

I have not yet heard from Quentin Rylee.

Tim Ray is on my list still.

The Vulnerability Assessment Report is still pending.

I removed and replaced the Ron Carey meter.

I checked the Journagin meter for a leak due to higher than Normal usage and found no leak. 772300

I informed Lacy Keenan that our responsibility stopped at the end the meter setter and her leak was her opportunity to make a Repair.

I'll be attending a three day Water Operators License requirement course at the Baxter County Training Facility the 17th Thru the 19th of January which will provide the needed hours for License renewal.

By Ivan Reynolds

Water Operator