

Dave Fenter
WWAC Chairman
101 East Capitol Avenue, Suite 350
Little Rock, Arkansas 72201



PHONE (501) 682-0543
FAX (501) 682-0561
E-MAIL dave.fenter@arkansas.gov
www.anrc.arkansas.gov/waterwastewater_advisory_commit.htm

State of Arkansas
WATER/WASTEWATER ADVISORY COMMITTEE

January 15, 2009

Mr. James Bowen
Mount Sherman Water Association
HCR 70 Box 250
Jasper, Arkansas 72641

Re: Mount Sherman's Pre-application for Recommendation on Water Funding

Dear Mr Bowen:

On January 14th, the Water/Wastewater Advisory Committee reviewed your pre-application for funding of water extension to 11 customers along Murray and Shiloh Roads. The Committee recommends funding be provided by the following agencies:

1. Arkansas Natural Resources Commission (ANRC)
2. Community Resource Group (CRG)
3. U.S. Dept. of Agriculture, Rural Development (RD)

The actual funding amounts cannot be determined at this time. The use of ANRC, CRG or RD loan funds would be up to you.

While this is not a comment, the National Pollutant Discharge Elimination System (NPDES) Branch of Arkansas Department of Environmental Quality's (ADEQ) Water Division has asked that we mention the need for a Storm Water Permit for construction. Any construction projects disturbing one (1) or more acres must have a storm water construction permit issued by ADEQ. The development of a Storm Water Pollution Prevention Plan is included as a permit requirement and must include the implementation of Best Management Practices (BMPs) during construction. These BMPs must include erosion and sediment control measures to prevent sediment from leaving the construction site.

We appreciate your cooperation with this pre-application process. If you have any questions or comments, please give me a call at the above telephone number.

Sincerely,

A handwritten signature in cursive script that reads "David Fenter".

David Fenter, Chairman
Water/Wastewater Advisory Committee

DF/nsb

cc: Tim Mays; Engineering Services, Inc.
WWAC Committee Members